

Part 1: Electrical Requirements

130) Unprotected Bus

An unprotected main bus may only be installed when the following conditions are met:

130.00.10) The design of the bus and all materials used in its construction shall be in accordance with We Energies requirements.

130.00.20) All taps from the bus shall be protected by We Energies accepted overcurrent devices.

130.00.30) Insulated cable is not allowed within the unprotected zone.

130.00.40) The circuit length of unprotected strain bus shall not exceed 25 feet without We Energies acceptance.