

Part 2: Physical Requirements

250) Enclosures, Fences, and Surfacing – Outdoor Open Type Substations

250.00.10) Customer shall furnish and install a suitable fence or enclosure for outdoor, open-type substations in accordance with the requirements of the Wisconsin and/or Michigan State Electrical Codes (all volumes) and/or applicable local codes and ordinances.

250.00.20) Initial fence construction and final grading shall be done carefully so as to close all voids between the bottom of fence or gate and final grade which may jeopardize the integrity of the enclosure. Also, reasonable maintenance shall be performed, as required, to close such voids which appear after the initial installation due to settling or erosion.

250.00.30) The Customer shall provide and install crushed limestone surfacing outside the substation fence when the fence ground is interconnected with the station ground grid as directed in Section 180.